

Thorough Examination Certificate For Scaffold

Company Name:	Chicago Maintenance And Const Co Llc	Contact Person	Mr. Suman	Contact Number	0556552628
Project Name	Ch]	Location	Dubai, Production City, Dubai Production City Near City Centre Meaisem	Inspector name	Usman Amjad
Inspection Item	Scaffold	Date of Inspection	2020-12-28	Date of Expiry	2021-06-28
Certificate Number	BSS-657	Type of Inspection	Periodic Inspection	Status	Safe
Location Details	Impz	Revision	0	Workorder	199

Scaffold-Description.

Type of scaffold	Cuplock system scaffold	Scaffold specification	Ledger= 2.5,1.8,m, Transom = 1.2m standard= 3.0 m
Scaffold classification (Duty type)	Light duty	Number of platform(s)	13
Number of bays	30	Number of supports	24 ties on each floor with beams and columns
Location	Elevation back side	Elevation	Back side
Grid Line (if available)	0-9/H	Operation height	G floor up to roof
Dimensions (L,W,H) m	1.20m, 60m, 25m	Last inspection date	26,12,2020
Weather conditions	Good	Additional information	Na
Inspection equipment(s)	MT6,DC,AM01	Accredited Standard	BS EN 12811-1:2003 , BS EN 12810-2:2003 , BS EN 12810-1: 2003 , BS EN 1004 :2004 , BS EN 1298:1996

Defects

defect description	
--------------------	--

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of **B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

Safe TO USE

and that the particular details are correct.

B Safe is a third party inspection Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althervation at the above details/description.

Deputy Technical Manager
ENG. Usman Amjad




Deputy Technical Manager
ENG. Usman Amjad



ENG-CH-12/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

Scaffold- checklist summery	
Ground condition and leveling	Safe
Supporting Elements	Safe
Safe Access	Safe
Structure condition	Safe
platform(s) condition	Safe
Side protection	Safe
Bracing	Safe
Supports	Safe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CH-12/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com