

Thorough Examination Report For False Work

Company Name:	City Nights Contracting Llc	Contact Person	Mr. Ritesh Kotian	Contact Number	0529805234
Project Name	Plot#375-3446	Location	Dubai, Al Nahda, Barsha Site	Inspector name	Ajith Raveendran
Inspection Item	False Work	Date of Inspection	2020-12-26	Date of Expiry	NA
Certificate Number	BSS-541	Type of Inspection	First Installation	Status	Unsafe
Location Details	Plot#375-3446	Revision	0	Workorder	377

False Work -Description	
Type of false work:	Cup lock Scaffold
False work specification	Ledger 1.8 m , standard 3 m
Slab thickness	250 mm
Slab for (floor number)	Roof slab
Location	Roof slab
Grid line	A-F/1-8
Clear height	7.2 m
Total area	900 sq.m
Inspection equipment(s)	MT 07,SL 02
Last inspection date (if available)	N/A
Weather conditions	Good
Additional information	N/A
Accredited Standards	BS 5975:2019 & BSS-INPR-019
Defects	
defect description	Missing ties and colours bracing missing

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of **B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

Unsafe TO USE

and that the particular details are correct.

B Safe is a third party inspeciton Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althervation at the above details/description.

ENG. Ajith Raveendran




Deputy Technical Manager

ENG. Usman Amjad



Inspection Details

False work-checklist summery	
Design verification	Safe
Foundation condition	Safe
standards, props conditions	Safe
standards-props to secondary beams connection	Safe
Secondary beams conditions	Safe
Locking members	Safe
Ties , Bracing condition	Unsafe
Bolts & pins	Safe
System verticality	Safe
lateral support and bracing	Unsafe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CH-14/V2/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com