

## Thorough Examination Certificate For False Work

Company Name:	<b>City Nights Contracting Llc</b>	Contact Person	<b>Ajith</b>	Contact Number	<b>0509057953</b>
Project Name	<b>Barsha 3</b>	Location	<b>Dubai, Al Barsha, Barsha 3</b>	Inspector name	<b>Ali Nasir Iqbal</b>
Inspection Item	<b>False Work</b>	Date of Inspection	<b>2020-12-17</b>	Date of Expiry	<b>2021-06-17</b>
Certificate Number	<b>BSS-41</b>	Type of Inspection	<b>Periodic Inspection</b>	Status	<b>Safe</b>
Location Details	<b>Plot # 3753427</b>	Revision	<b>0</b>	Workorder	<b>129</b>

False Work -Description	
Type of false work:	Adjustable steel props
False work specification	Spacing between Jack's 1.3*1.0m
Slab thickness	28cm
Slab for (floor number)	Water tank and basement slab
Location	Water tank and basement slab
Grid line	(D-I)1-8)
Clear height	2.77m
Total area	250m <sup>2</sup>
Inspection equipment(s)	MT-29 LDM-28
Last inspection date (if available)	N/A
Weather conditions	Good
Additional information	Drawing # DBC\A\2020\539
Accredited Standards	BS 5975:2019 & BSS-INPR-019

### Defects

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of

**B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

**Safe TO USE**

and that the particuler details are correct.

*B Safe is a third party inspeciton Type A Inspection Body*

The item/equipment should be re-tested in case of any major repair and/or althernation at the above details/description.

ENG. Ali Nasir Iqbal



Deputy Technical Manager  
ENG. Usman Amjad

ENG-CH-14/V2/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

## Inspection Details

False work-checklist summery	
Design verification	Safe
Foundation condition	Safe
standards, props conditions	Safe
standards-props to secondary beams connection	Safe
Secondary beams conditions	Safe
Locking members	Safe
Ties , Bracing condition	Safe
Bolts & pins	Safe
System verticality	Safe
lateral support and bracing	Safe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

**B SAFE safety consultancy** will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

**ENG-CH-14/V2/2020-12-18**

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : [info@bsafesafety.com](mailto:info@bsafesafety.com) DUBAI SILICON OASIS - PALACE TOWER 1

[www.bsafesafety.com](http://www.bsafesafety.com)