

Thorough Examination Report For Scaffold

Company Name:	City Nights Contracting Llc	Contact Person	Mr. Ritesh Kotian	Contact Number	0529805234
Project Name	Plot#3753431	Location	Al Barsha ,dubai	Inspector name	Ajith Raveendran
Inspection Item	Scaffold	Date of Inspection	2020-12-31	Date of Expiry	NA
Certificate Number	BSS-1431	Type of Inspection	Periodic Inspection	Status	Unsafe
Location Details	Plot#3753431	Revision	0	Workorder	600

Scaffold-Description.

Type of scaffold	Cup lock scaffold	Scaffold specification	Led-2.5 m,std-3 m
Scaffold classification (Duty type)	N/A	Number of platform(s)	05
Number of bays	09	Number of supports	Through ties with wall
Location	Back side	Elevation	Back
Grid Line (if available)	N/A	Operation height	20 m
Dimensions (L,W,H) m	Length 20m Width 1.3m Height 12m	Last inspection date	N/A
Weather conditions	Good	Additional information	No
Inspection equipment(s)	MT 07 and SL02	Accredited Standard	BS EN 12811-1:2003 , BS EN 12810-2:2003 , BS EN 12810-1: 2003 , BS EN 1004 :2004 , BS EN 1298:1996

Defects

defect description	Improper ties There is proper Access so failed to perform further more inspection Missing midrails Improper foundation
--------------------	---

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of

B SAFE SAFETY & SECURITY CONSULTANCY that the item(s)/equipment described in this certificate is/are

Unsafe TO USE

and that the particular details are correct.

B Safe is a third party inspection Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or altharnation at the above details/description.

ENG. Ajith Raveendran



Deputy Technical Manager
ENG. Usman Amjad

ENG-CH-12/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

Scaffold- checklist summery	
Ground condition and leveling	Unsafe
Supporting Elements	Unsafe
Safe Access	Unsafe
Structure condition	Safe
platform(s) condition	Safe
Side protection	Unsafe
Bracing	Safe
Supports	Unsafe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CH-12/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com