



B SAFE SAFETY & SECURITY CONSULTANCY

INSPECTION, TRAINING, CONSULTANTS

Thorough Examination Certificate For Pull Out Test

Company Name:	City Nights Contracting Llc	Contact Person	Mr. Ritesh Kotian	Contact Number	0529805234
Project Name	Dip 2	Location	Dubai, Al Nahda, Dip 2	Inspector name	Rejin Antony
Inspection Item	Pull Out Test For Steel Bar C-hook	Date of Inspection	2020-12-20	Date of Expiry	2021-12-19
Certificate Number	BSS-113	Type of Inspection	Periodic Inspection	Status	Safe
Location Details	Plot No:5974248, Dip 2, Dxb, Uae.,	Revision	0	Workorder	103

pull Out test - Description			
Pull item type	Steel Bar C-hook running from the slab	Base material type	Steel
Embedded length	160mm	Embedded depth	260mm
Position	Verical	Pull out force	2 ton
Elongation	Nil	Diameter/size	25mm
Orientations (vertical- horizontal)	Vertical	Quantity	14
Serial number(s)	Lift 2 & Lift 3	References	BS 5080-1 , BS 5080-2 , BS 8539 , ASTM C900-01,ASTM C900-99
Location	Lift Shaft, Roof	Environmental conditions	Good
Date of previous pullout test	Nil	Instruments used	POT-02
Subcontracting parts	Nil	Report number for any supplementary tests	Nil
Date of previous load/proof test (if any)	Nil	Additional information	Nil
Any major repair if found/details	Nil	High Recommendations	Nil
Defects			
defect description	Nil		

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of

B SAFE SAFETY & SECURITY CONSULTANCY that the item(s)/equipment described in this certificate is/are

Safe TO USE

and that the particuler details are correct.

B Safe is a third party inspeciton Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althernation at the above details/description.

ENG. Rejin Antony



Deputy Technical Manager
ENG. Usman Amjad

ENG-CH-4/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CH-4/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com