

Thorough Examination Certificate For Cradle

Company Name:	X Platform	Contact Person	Mr. Ahmed	Contact Number	0551087354
Project Name	Tech Tower	Location	Ajman, Jurf, Ajman	Inspector name	Danial Naseer
Inspection Item	Cradle	Date of Inspection	2020-12-17	Date of Expiry	2021-06-17
Certificate Number	BSS-33	Type of Inspection	Periodic Inspection	Status	Safe
Location Details	Tech Tower	Revision	0	Workorder	125

Cradle-Description

Proof load applied	312.5Kg	Manufacture	XPLATFORM
Model	XII	Span	6.0m+1.0m
Operation height	Ground to Roof	Elevation	2
Support description	Supported on roof by parapet clamps by 6 bolts on each	Serial number(Platform)	24
S. No motors	615B0056,615B0222	S. No safety devices	1321127,171456
Safe working load (SWL)	250 Kg	Location	Supported on roof
Grindlines(if provided)	N/A	Accredited Standard and Procedure	BS EN 1808:2015 , BSS-INPR-002
NDT (If required)	N/A	Instruments used in inspection	MT35,DC37
Subcontract Parts	N/A	Environment Conditions during inspection	Good
Last Inspection Date	N/A	Additional comments (If any)	N/A
Any major repair if found / detail	N/A		

Defects

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of **B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

Safe TO USE

and that the particular details are correct.

B Safe is a third party inspection Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althervation at the above details/description.

ENG. Danial Naseer



Deputy Technical Manager
ENG. Usman Amjad

ENG-CR-2/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

Cradle-Electrical Test

Cradle-Suspended Platform

Guardrails, intermediate rails and toe boards shall be free for deformation or distortion or missing	Safe
Wall rollers , caster wheels	Safe

Cradle-Hoisting System

Service brake activated, no displace found under normal working conditions.	Safe
No power descent , maximum angle is 14deg	Safe
Tensioning device for wire rope	Safe

Cradle-Limit Switches

Anti-tilt device	Safe
Lifting limit switch	Safe
All of trolley motions (traversing, slewing, and telescoping) shall be provided with limit switch.	Safe

Cradle-Secondary Devices

Cradle-Wire Rope

Cradle-General Requirements

Cradle-Documents required

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be returned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CR-2/V1/2020-12-18

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com