

Thorough Examination Certificate For Cradle

Company Name:	Dubai Properties	Contact Person	Mr. Jayapandi	Contact Number	0552056215
Project Name	Bbet	Location	Dubai, Business Bay, Bbet	Inspector name	Ajith Raveendran
Inspection Item	Cradle	Date of Inspection	2020-12-24	Date of Expiry	2021-06-24
Certificate Number	BSS-777	Type of Inspection	Periodic Inspection	Status	Safe
Location Details	Tower H	Revision	0	Workorder	328

Cradle-Description			
Manufacture	MaltTechnics	Model	MSC200D
Serial number(Platform)	35-154-07	S. No motors	5310722
S. No safety devices	N/A	Span	2 m
Operation height	First floor to roof	Elevation	Around building
Support description	Rail tracks swing jib post trolley mounted,suspended Access Equipment (BMU)	Safe working load (SWL)	200 kg
Proof load applied	250 kg	Location	Top roof
Grindlines(if provided)	N/A	Accredited Standard and Procedure	BS EN 1808:2015 , BSS-INPR-002
NDT (If required)	N/A	Instruments used in inspection	MT07-SL02
Subcontract Parts	N/A	Environment Conditions during inspection	Good
Last Inspection Date	N/A	Additional comments (If any)	N/A
Any major repair if found / detail	Good		
Defects			
defect description	No		

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of **B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

Safe TO USE

and that the particular details are correct.

B Safe is a third party inspection Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althervation at the above details/description.

ENG. Ajith Raveendran



Deputy Technical Manager
ENG. Usman Amjad

ENG-CR-2/V8/2020-12-28

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

Cradle-Electrical Test	
No damage to panel enclosure	Safe
Condition of the wires and distribution board	Safe
Cradle-Suspended Platform	
Guardrails, intermediate rails and toe boards shall be free for deformation or distortion or missing	Safe
Wall rollers , caster wheels	Safe
Cradle-Hoisting System	
Service brake activated, no displace found under normal working conditions.	Safe
No power descent , maximum angle is 14deg	Safe
Tensioning device for wire rope	Safe
Cradle-Limit Switches	
Anti-tilt device	Safe
Lifting limit switch	Safe
All of trolley motions (traversing, slewing, and telescoping) shall be provided with limit switch.	NA
Cradle-General Requirements	
Labeling for SWL , and WLL on the hoist	Safe
Serial numbers of hoists , secondary devices and control box	Safe
Electrical wiring diagram for the control box	Safe
Warning signs inside the platform	Safe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be retuned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

ENG-CR-2/V8/2020-12-28

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com