

Thorough Examination Certificate For Cradle

Company Name:	Seddiqi Properties	Contact Person	Gladys Shane	Contact Number	045118648
Project Name	Emerald Residence	Location	Dubai, Sheikh Zayed Road, Emerald Residence Site	Inspector name	Omar Masoud
Inspection Item	Cradle	Date of Inspection	2021-01-13	Date of Expiry	2021-07-13
Certificate Number	BSS-2676	Type of Inspection	Periodic Inspection	Status	Safe
Location Details	Dso	Revision	0	Workorder	936

Cradle-Description			
Manufacture	Transwill	Model	Tw_c
Serial number(Platform)	309	S. No motors	07160111 08160113
S. No safety devices	4173654 4173658	Span	2m
Operation height	Group to roof	Safe working load (SWL)	250kg
Proof load applied		Elevation	
Support description		Location	
Grindlines(if provided)		Accredited Standard and Procedure	BS EN 1808:2015 , BSS-INPR-002
NDT (If required)		Instruments used in inspection	
Subcontract Parts		Environment Conditions during inspection	
Last Inspection Date		Additional comments (If any)	
Any major repair if found / detail			

Defects	
defect description	

All the inspections results relates exclusively to work ordered or objects or lot inspected and inspection certificates/reports shall not be reproduced except in full without approval of inspection body and the client. B SAFE has legal indemnity against all losses, accidents and damages on site arising due to faulty inspection activities during the work. we certify on behalf of **B SAFE SAFETY & SECURITY CONSULTANCY** that the item(s)/equipment described in this certificate is/are

Safe TO USE

and that the particular details are correct.


B Safe is a third party inspection Type A Inspection Body

The item/equipment should be re-tested in case of any major repair and/or althervation at the above details/description.
Please note that Below Signature & Stamping are generated & Approved Electronically.

Inspection Engineer
ENG. Omar Masoud




Deputy Technical Manager
ENG. Jaman Amjad



ENG-CR-2/V8/2020-12-28

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com

Inspection Details

Cradle-Electrical Test	
No damage to panel enclosure	Safe
Condition of the wires and distribution board	Safe
Cradle-Suspended Platform	
Guardrails, intermediate rails and toe boards shall be free for deformation or distortion or missing	Safe
Wall rollers , caster wheels	Safe
Cradle-Hoisting System	
Service brake activated, no displace found under normal working conditions.	Safe
No power descent , maximum angle is 14deg	Safe
Tensioning device for wire rope	Safe
Cradle-Limit Switches	
Anti-tilt device	Safe
Lifting limit switch	Safe
All of trolley motions (traversing, slewing, and telescoping) shall be provided with limit switch.	Safe
Cradle-General Requirements	
Labeling for SWL , and WLL on the hoist	Safe
Serial numbers of hoists , secondary devices and control box	Safe
Electrical wiring diagram for the control box	Safe
Warning signs inside the platform	Safe

In providing services information or advice B SAFE safety consultancy does not warrant the accuracy of any information or advice supplied by the end user , and shall not be liable for any loss, damage or expense whatever sustained by any person due to any act of mis-operation/ mis-handled.

It should be also understood and agreed that all contained information in this report shall not be considered to relieve any designer, manufacturer, supplier, seller, repairer or operator of any warranty, expressed or implied.

B SAFE safety consultancy will not support the validity of any certificate if it has been found that the item described has been mistreated, overloaded, impact loaded, misoperated, misused or shock loaded.

This certificate is the property of B safe safety & security consultancy and shall be retuned on demand.

THIS REPORT HAS BEEN ISSUED WITHOUT PREJUDICE TO ANY PARTY INVOLVED

For Certificate Verification, Please Visit Our Website: BsafeSafety.com

ENG-CR-2/V8/2020-12-28

Tel : +971 4 320 94 94 FAX: +971 4 320 94 95 P.O.BOX : 300465 DUBAI - UAE

E.MAIL : info@bsafesafety.com DUBAI SILICON OASIS - PALACE TOWER 1

www.bsafesafety.com